



BOILING SPRINGS FIRE DISTRICT

5020 PELHAM ROAD GREENVILLE, S.C. 29615

Jeff Nelson, CFM, IAAI-FIT

Phone (864) 268-3617

Fax (864) 268-3691

jnelson@boilingspringsfd.org

FIRE SPRINKLER PLAN REVIEW REQUIREMENTS

Boiling Springs Fire District reviews all fire sprinkler plan submittals for compliance with the currently adopted edition of the International Fire Code and referenced standards, including NFPA 13, 13R & 13D.

1. Any fire sprinkler system installation or modification performed in South Carolina must meet all the requirements of The South Carolina Fire Protection Sprinkler Systems Act. The main requirements of this law are as follows:

- *The South Carolina Fire Protection Sprinkler Systems Act, Section 40-10-260 (A) requires that sprinkler system shop drawings must be prepared for every fire protection sprinkler system to be installed in South Carolina. Shop drawings along with any specification sheets must be submitted to the local authority having jurisdiction (Boiling Springs Fire District Fire Marshal) for review.*
 - *The South Carolina Fire Protection Sprinkler Systems Act, section 40-10-250, requires that a "Fire Sprinkler System Specification Sheet", approved by the State Fire Marshal, be completed for every fire protection sprinkler system to be installed in South Carolina. This specification sheet must be submitted to the local authority having jurisdiction (Boiling Springs Fire District Fire Marshal) for review.*
 - *The South Carolina Fire Protection Sprinkler Act, section 40-10-260 (D), requires that a "Certificate of Compliance" certifying that the fire protection sprinkler system was designed and installed in accordance with the "Fire Sprinkler Specification Sheet" must be delivered to the local authority having jurisdiction (Boiling Springs Fire District Fire Marshal).*
2. At a minimum, architectural or engineered sprinkler plans and the design criteria must be submitted.

The sprinkler shop drawings and calculations must be submitted for review and approval prior to the building rough-in inspection.

3. Only fire sprinkler contractors licensed by the SC Department of Labor, Licensing and Regulation (SCLLR) are permitted to perform sprinkler installations or modifications in South Carolina.
4. Plans and specifications should be delivered to the Boiling Springs Fire District Fire Marshal.
5. Fire sprinkler plans and specifications must also be sent to SCLLR, Division of Fire and Life Safety. The SCLLR, Division of Fire and Life Safety may be reached at 1-800-896-1070

For further information, please contact the Boiling Springs Fire District Fire Marshal.